

PROPOSAL REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-13-R-0135

NOTE: ALL PRE-PROPOSAL INQUIRIES SHALL BE SUBMITTED VIA EMAIL TO karen.smith3@va.gov BY AN EDITABLE USE OF THIS FORM. Please identify, in numerical sequence, each set of inquiries that you send.

Question(s) is/are on the solicitation [☐]

Question(s) is/are on the drawings, specifications, technical data [☒]

Company Name and Offeror: Herman Construction Group_____

From (person submitting question): Rick Garcia_____

Date of Proposal Inquiry: 7/9/13_____

Phone Number: (619) 964-9274_____

Proposal Inquiry: (Type inquiry below)

Proposal RFI #2 – Please confirm the Norament Grano (resilient rubber tile) is to be integrally coved in all areas, including stairs.

HDR Response 7.9.2013: NO, Norament Grano tiles do not have an integral cove base. As per the Material Legend on sheet A-630, there is an RB (Resilient Rubber Base) that clearly indicates 'Typical U.O.N.'

Proposal RFI #3 -

Add additional as necessary